



13 October 2021

ASTI - BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL BULLETIN NO. BAC-2021-010-018

SUPPLY, DELIVERY AND INSTALLATION OF WATERPROOFING AT DOST-ASTI ROOFDECK

The ASTI Bids and Awards Committee (BAC) issues this Supplemental/Bid Bulletin to clarify, modify or amend items in the Bidding Documents and to reply to queries raised by the potential bidders through letters/emails for the information of all bidders for the procurement of:

Item: **Supply, Delivery, and Installation of Waterproofing of DOST-ASTI Roofdeck**
 Approved Budget for the Contract: **Four Million Pesos Only (₱4,000,000.00)**
 Invitation to Bid No.: **21-09-3564 dated 30 September 2021**
 Purchase Request Nos.: **GAA-21-09-12061 dated 09 September 2021**
 Published Date (PhilGEPS): **01 October 2021 | 8045106**

A. AMENDMENT TO PROCUREMENT DETAILS AND FORMS

REFERENCE	AMENDMENT/CHANGE/CLARIFICATION										
Section III. Bid Data Sheet, Clause 10.5, Page 19	FROM:										
	<table border="1"> <thead> <tr> <th>ITB Clause</th> <th></th> </tr> </thead> <tbody> <tr> <td>10.5</td> <td>The minimum major equipment requirements are the following: <table border="1"> <thead> <tr> <th>Equipment</th> <th>Capacity</th> <th>Number of Units</th> </tr> </thead> <tbody> <tr> <td colspan="3"> <ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 lbs. jackhammer or demolition hammer to remove old concrete topping. </td> </tr> </tbody> </table> </td> </tr> </tbody> </table>	ITB Clause		10.5	The minimum major equipment requirements are the following: <table border="1"> <thead> <tr> <th>Equipment</th> <th>Capacity</th> <th>Number of Units</th> </tr> </thead> <tbody> <tr> <td colspan="3"> <ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 lbs. jackhammer or demolition hammer to remove old concrete topping. </td> </tr> </tbody> </table>	Equipment	Capacity	Number of Units	<ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 lbs. jackhammer or demolition hammer to remove old concrete topping. 		
ITB Clause											
10.5	The minimum major equipment requirements are the following: <table border="1"> <thead> <tr> <th>Equipment</th> <th>Capacity</th> <th>Number of Units</th> </tr> </thead> <tbody> <tr> <td colspan="3"> <ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 lbs. jackhammer or demolition hammer to remove old concrete topping. </td> </tr> </tbody> </table>	Equipment	Capacity	Number of Units	<ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 lbs. jackhammer or demolition hammer to remove old concrete topping. 						
Equipment	Capacity	Number of Units									
<ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 lbs. jackhammer or demolition hammer to remove old concrete topping. 											
TO:											
	<table border="1"> <thead> <tr> <th>ITB Clause</th> <th></th> </tr> </thead> <tbody> <tr> <td>10.5</td> <td>The minimum major equipment requirements are the following: <table border="1"> <thead> <tr> <th>Equipment</th> <th>Capacity</th> <th>Number of Units</th> </tr> </thead> <tbody> <tr> <td colspan="3"> <ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 fifteen (15) lbs. jackhammer or demolition hammer to remove old concrete topping. </td> </tr> </tbody> </table> </td> </tr> </tbody> </table>	ITB Clause		10.5	The minimum major equipment requirements are the following: <table border="1"> <thead> <tr> <th>Equipment</th> <th>Capacity</th> <th>Number of Units</th> </tr> </thead> <tbody> <tr> <td colspan="3"> <ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 fifteen (15) lbs. jackhammer or demolition hammer to remove old concrete topping. </td> </tr> </tbody> </table>	Equipment	Capacity	Number of Units	<ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 fifteen (15) lbs. jackhammer or demolition hammer to remove old concrete topping. 		
ITB Clause											
10.5	The minimum major equipment requirements are the following: <table border="1"> <thead> <tr> <th>Equipment</th> <th>Capacity</th> <th>Number of Units</th> </tr> </thead> <tbody> <tr> <td colspan="3"> <ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 fifteen (15) lbs. jackhammer or demolition hammer to remove old concrete topping. </td> </tr> </tbody> </table>	Equipment	Capacity	Number of Units	<ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 fifteen (15) lbs. jackhammer or demolition hammer to remove old concrete topping. 						
Equipment	Capacity	Number of Units									
<ul style="list-style-type: none"> Two (2) units truck for hauling, disposal, delivery, mobilization and/or demobilization; and Three (3) units 20 fifteen (15) lbs. jackhammer or demolition hammer to remove old concrete topping. 											
Section V. Special Conditions of Contract, Clause 7.2, Page 27	FROM:										
	<table border="1"> <thead> <tr> <th>GCC Clause</th> <th></th> </tr> </thead> <tbody> <tr> <td>7.2</td> <td>In case of semi-permanent structures, such as buildings of types 1, 2, and 3 as classified under the National Building Code of the Philippines, concrete/asphalt roads, concrete river control, drainage, irrigation lined canals, river landing, deep wells, rock causeway, pedestrian overpass, and other similar semi-permanent structures: Ten (10) years</td> </tr> </tbody> </table>	GCC Clause		7.2	In case of semi-permanent structures, such as buildings of types 1, 2, and 3 as classified under the National Building Code of the Philippines, concrete/asphalt roads, concrete river control, drainage, irrigation lined canals, river landing, deep wells, rock causeway, pedestrian overpass, and other similar semi-permanent structures: Ten (10) years						
GCC Clause											
7.2	In case of semi-permanent structures, such as buildings of types 1, 2, and 3 as classified under the National Building Code of the Philippines, concrete/asphalt roads, concrete river control, drainage, irrigation lined canals, river landing, deep wells, rock causeway, pedestrian overpass, and other similar semi-permanent structures: Ten (10) years										
TO:											
	<table border="1"> <thead> <tr> <th>GCC Clause</th> <th></th> </tr> </thead> <tbody> <tr> <td>7.2</td> <td>In case of semi-permanent structures, such as buildings of types 1, 2, and 3 as classified under the National Building Code of the Philippines, concrete/asphalt roads, concrete river control, drainage, irrigation lined canals, river landing, deep wells, rock causeway, pedestrian overpass, and other similar semi-permanent structures: Ten (10) Five (5) years</td> </tr> </tbody> </table>	GCC Clause		7.2	In case of semi-permanent structures, such as buildings of types 1, 2, and 3 as classified under the National Building Code of the Philippines, concrete/asphalt roads, concrete river control, drainage, irrigation lined canals, river landing, deep wells, rock causeway, pedestrian overpass, and other similar semi-permanent structures: Ten (10) Five (5) years						
GCC Clause											
7.2	In case of semi-permanent structures, such as buildings of types 1, 2, and 3 as classified under the National Building Code of the Philippines, concrete/asphalt roads, concrete river control, drainage, irrigation lined canals, river landing, deep wells, rock causeway, pedestrian overpass, and other similar semi-permanent structures: Ten (10) Five (5) years										

<p>Section V. Special Conditions of Contract, Clause 7.2, Page 27-28</p>	<p>FROM:</p> <table border="1" data-bbox="423 219 1471 608"> <thead> <tr> <th data-bbox="423 219 594 251">GCC Clause</th> <th data-bbox="594 219 1471 251"></th> </tr> </thead> <tbody> <tr> <td data-bbox="423 251 594 608">15.2</td> <td data-bbox="594 251 1471 608"> <p>The following shall be submitted to DOST-ASTI:</p> <ul style="list-style-type: none"> a) As-built Plans. The Contractor shall submit shop drawings. A complete set of As Built Drawings printed form (20" x 30") and/or A3 and an electronic copy in AutoCAD; b) Flood test results/reports and duration of which must be 48 hours upon application of waterproofing; c) Original Copy of "Record Drawing/Plan" complete with legend, technical specifications, and measurements; d) Final Project Report including photo documentations before, during and after implementation works. Each photo documentation should have the date and time stamps in jpg format; and e) Warranty Certificate of at least ten (10) years against poor workmanship and defects traceable to materials </td> </tr> </tbody> </table> <p>TO:</p> <table border="1" data-bbox="423 692 1471 1081"> <thead> <tr> <th data-bbox="423 692 594 725">GCC Clause</th> <th data-bbox="594 692 1471 725"></th> </tr> </thead> <tbody> <tr> <td data-bbox="423 725 594 1081">15.2</td> <td data-bbox="594 725 1471 1081"> <p>The following shall be submitted to DOST-ASTI:</p> <ul style="list-style-type: none"> a) As-built Plans. The Contractor shall submit shop drawings. A complete set of As Built Drawings printed form (20" x 30") and/or A3 and an electronic copy in AutoCAD; b) Flood test results/reports and duration of which must be forty-eight (48) hours upon application of waterproofing; c) Original Copy of "Record Drawing/Plan" complete with legend, technical specifications, and measurements; d) Final Project Report including photo documentations before, during and after implementation works. Each photo documentation should have the date and time stamps in jpg format; and e) Warranty Certificate of at least ten (10) five (5) years against poor workmanship and defects traceable to materials </td> </tr> </tbody> </table>	GCC Clause		15.2	<p>The following shall be submitted to DOST-ASTI:</p> <ul style="list-style-type: none"> a) As-built Plans. The Contractor shall submit shop drawings. A complete set of As Built Drawings printed form (20" x 30") and/or A3 and an electronic copy in AutoCAD; b) Flood test results/reports and duration of which must be 48 hours upon application of waterproofing; c) Original Copy of "Record Drawing/Plan" complete with legend, technical specifications, and measurements; d) Final Project Report including photo documentations before, during and after implementation works. Each photo documentation should have the date and time stamps in jpg format; and e) Warranty Certificate of at least ten (10) years against poor workmanship and defects traceable to materials 	GCC Clause		15.2	<p>The following shall be submitted to DOST-ASTI:</p> <ul style="list-style-type: none"> a) As-built Plans. The Contractor shall submit shop drawings. A complete set of As Built Drawings printed form (20" x 30") and/or A3 and an electronic copy in AutoCAD; b) Flood test results/reports and duration of which must be forty-eight (48) hours upon application of waterproofing; c) Original Copy of "Record Drawing/Plan" complete with legend, technical specifications, and measurements; d) Final Project Report including photo documentations before, during and after implementation works. Each photo documentation should have the date and time stamps in jpg format; and e) Warranty Certificate of at least ten (10) five (5) years against poor workmanship and defects traceable to materials
GCC Clause									
15.2	<p>The following shall be submitted to DOST-ASTI:</p> <ul style="list-style-type: none"> a) As-built Plans. The Contractor shall submit shop drawings. A complete set of As Built Drawings printed form (20" x 30") and/or A3 and an electronic copy in AutoCAD; b) Flood test results/reports and duration of which must be 48 hours upon application of waterproofing; c) Original Copy of "Record Drawing/Plan" complete with legend, technical specifications, and measurements; d) Final Project Report including photo documentations before, during and after implementation works. Each photo documentation should have the date and time stamps in jpg format; and e) Warranty Certificate of at least ten (10) years against poor workmanship and defects traceable to materials 								
GCC Clause									
15.2	<p>The following shall be submitted to DOST-ASTI:</p> <ul style="list-style-type: none"> a) As-built Plans. The Contractor shall submit shop drawings. A complete set of As Built Drawings printed form (20" x 30") and/or A3 and an electronic copy in AutoCAD; b) Flood test results/reports and duration of which must be forty-eight (48) hours upon application of waterproofing; c) Original Copy of "Record Drawing/Plan" complete with legend, technical specifications, and measurements; d) Final Project Report including photo documentations before, during and after implementation works. Each photo documentation should have the date and time stamps in jpg format; and e) Warranty Certificate of at least ten (10) five (5) years against poor workmanship and defects traceable to materials 								
<p>Section VI. Specifications, Page 33</p>	<p>FROM:</p> <p>10. WARRANTY</p> <p>10.1. Special Manufacturer's Warranty: Manufacturer's standard form in which waterproofing manufacturer and installer agree to repair or replace waterproofing that does not comply with requirements or that fails to remain watertight within specified warranty period.</p> <p>10.1.1. Warranty does not include failure of waterproofing due to failure of substrate prepared and treated according to requirements or formation of new joints and cracks in substrate that exceed 1.6mm in width.</p> <p>10.1.2. Warranty period of ten (10) years from date of Substantial Completion.</p> <p>TO:</p> <p>10. WARRANTY</p> <p>10.1. Special Manufacturer's Warranty: Manufacturer's standard form in which waterproofing manufacturer and installer agree to repair or replace waterproofing that does not comply with requirements or that fails to remain watertight within specified warranty period.</p> <p>10.1.1. Warranty does not include failure of waterproofing due to failure of substrate prepared and treated according to requirements or formation of new joints and cracks in substrate that exceed 1.6mm in width.</p> <p>10.1.2. Warranty period of ten (10) five (5) years from date of Substantial Completion.</p>								
<p>Section IX. Checklist of Technical and Financial Documents, Page 48</p>	<p>FROM:</p> <p><u>Technical Documents</u></p> <p>(j) Project Requirements, which shall include the following:</p> <ul style="list-style-type: none"> a. Organizational chart for the contract to be bid; b. List of contractor's key personnel (e.g., Project Manager, Project Engineers, Materials Engineers, and Foremen), to be assigned to the contract to be bid, with their complete qualification and experience data; c. List of contractor's major equipment units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership or certification of availability of equipment from the equipment lessor/vendor for the duration of the project, as the case may be; and <p>TO:</p> <p><u>Technical Documents</u></p> <p>(j) Project Requirements, which shall include the following:</p>								

	<ul style="list-style-type: none"> a. Organizational chart for the contract to be bid; b. List of contractor's key personnel (e.g., Project Manager, Project Engineers, Materials Engineers, and Foremen), to be assigned to the contract to be bid, with their complete qualification and experience data; c. List of contractor's major equipment units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership or certification of availability of equipment from the equipment lessor/vendor for the duration of the project, as the case may be; d. Company profile with list of present and previous clientele for the past five (5) years; e. Duly signed resume/curriculum vitae of contractor's Key Personnel; f. Duly notarized Affidavit of Commitment from the bidder's Key Personnel; g. Duly signed Work Schedule; h. Duly signed Delivery Schedule; i. Duly signed Table of Organization; j. Duly signed Manpower Schedule; k. Duly signed Samples Product Data; l. Duly signed Safety Plan; m. Duly signed Construction Methodology; and n. Certificate of Site Inspection issued by the manager or his/her authorized representative; o. Duly conformed Terms of Reference under Section VI. Technical Specifications; p. Duly conformed Bill of Quantities under Section VIII. Bill of Quantities; <u>and</u>
--	--

B. RESPONSE TO QUERIES

QUERY/ISSUE	BAC/END-USER RESPONSE/CLARIFICATION
10.3 of the Bid Data Sheet, it says that "with a classification General Engineering (GE-1) or Specialty – Waterproofing Work (SP-WP)". Would this mean that either of the two is acceptable?	Yes, either of the two requirements is acceptable.
Is it acceptable to the Procuring Entity if the Project-in-Charge is also a Safety Officer?	Yes, it is acceptable. Details must be reflected in the duly signed resume/curriculum vitae of the personnel.
What is the required number of hours for flood testing?	Forty-eight (48) hours flood testing is required. The result must be submitted as provided for in Clause 15.2 of Section V. Special Conditions of Contract.
Are we allowed to use the forms that we usually use in joining public biddings of other government agencies?	Attached in this Supplemental Bulletin are the forms prescribed by the Government Procurement Policy Board (GPPB) thru GPPB Circular 04-2020 dated 16 September 2020 and the Procuring Entity. Forms can be downloaded from the GPPB website through: https://www.gppb.gov.ph/downloadables.php .

ADDITIONAL INSTRUCTION/S: Prospective bidder/s are required to amend the form to update existing information.

Please be guided accordingly.

Prepared by:

KATHERINE B. RAMOS
Head, BAC Secretariat

Approved by:

GERWIN P. GUBA
Chairperson, BAC