



06 March 2023

ASTI - BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL BULLETIN NO. BAC-2023-03-004

SUPPLY, DELIVERY, AND INSTALLATION OF ONE (1) LOT COOLING AND POWER MANAGEMENT SYSTEM

The ASTI Bids and Awards Committee (BAC) issues this Supplemental/Bid Bulletin to clarify, modify or amend items in the Bidding Documents and to reply to queries raised by the potential bidders through letters/emails for the information of all bidders for the procurement of:

Item:	Supply, Delivery, and Installation of One (1) Lot Cooling and Power Management System
Approved Budget for the Contract:	Fifteen Million Pesos Only (₱15,000,000.00)
Invitation to Bid No.:	23-02-4254 dated 21 February 2023
Purchase Request No.:	QCS-22-09-15004 dated 16 September 2023
Published Date (PhilGEPS):	22 February 2023 9503896

A. AMENDMENT TO PROCUREMENT DETAILS AND FORMS

REFERENCE	AMENDMENT/CHANGE/CLARIFICATION															
Section III. Bid Data Sheet, Page 18	<p>FROM:</p> <p>For this purpose, contracts similar to the Project shall be:</p> <ul style="list-style-type: none"> a. Supply, Delivery, and Installation of Cooling and Power Management System; and b. completed within three (3) years, specifically from 13 March 2020 to 12 March 2023 prior to the deadline for the submission and receipt of bids. <p>TO:</p> <p>For this purpose, contracts similar to the Project shall be:</p> <ul style="list-style-type: none"> a. Supply, Delivery, and Installation of Cooling and Power Management System or Supply and Delivery of ICT-related Equipment or Infrastructure; and b. completed within three (3) years, specifically from 13 March 2020 to 12 March 2023 prior to the deadline for the submission and receipt of bids. 															
Section VII. Technical Specifications, Page 31-32	<p>FROM:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">ITEM NO.</th> <th style="text-align: center;">SPECIFICATIONS</th> <th style="text-align: center;">STATEMENT OF COMPLIANCE</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td>Cooling and Power Management System</td> <td></td> </tr> <tr> <td></td> <td>3. Other Specifications</td> <td></td> </tr> <tr> <td></td> <td>3.2. Supply and installation of electrical THHN wires, including MDP assembly, 1-unit 100kVA dry type transformer for PACU and additional 20kVA transformer for existing 80kVA transformer, PACU PP assembly, UPS Input & Output PP, ECBs, RSC pipe, flexible liquid tight, and other consumable materials.</td> <td></td> </tr> <tr> <td></td> <td>4. Warranty and After Sales Support</td> <td></td> </tr> </tbody> </table>	ITEM NO.	SPECIFICATIONS	STATEMENT OF COMPLIANCE	1	Cooling and Power Management System			3. Other Specifications			3.2. Supply and installation of electrical THHN wires, including MDP assembly, 1-unit 100kVA dry type transformer for PACU and additional 20kVA transformer for existing 80kVA transformer, PACU PP assembly, UPS Input & Output PP, ECBs, RSC pipe, flexible liquid tight, and other consumable materials.			4. Warranty and After Sales Support	
ITEM NO.	SPECIFICATIONS	STATEMENT OF COMPLIANCE														
1	Cooling and Power Management System															
	3. Other Specifications															
	3.2. Supply and installation of electrical THHN wires, including MDP assembly, 1-unit 100kVA dry type transformer for PACU and additional 20kVA transformer for existing 80kVA transformer, PACU PP assembly, UPS Input & Output PP, ECBs, RSC pipe, flexible liquid tight, and other consumable materials.															
	4. Warranty and After Sales Support															

	4.1. Two (2) years, with quarterly PMS during warranty period.	
TO:		
ITEM NO.	SPECIFICATIONS	STATEMENT OF COMPLIANCE
1	Cooling and Power Management System	
	3. Other Specifications	
	3.2. Supply and installation of electrical THHN wires, including MDP assembly, 1-unit 100kVA dry type transformer for PACU and additional 20kVA transformer for existing 80kVA transformer , PACU PP assembly, UPS Input & Output PP, ECBs, RSC pipe, flexible liquid tight, and other consumable materials.	
	4. Warranty and After Sales Support	
	4.1. Two (2) years, with quarterly semi-annual PMS during warranty period.	
Section VIII. Checklist of Technical and Financial Documents, Page 35	FROM:	
	II. FINANCIAL COMPONENT ENVELOPE	
	<input type="checkbox"/> (a) Original of duly signed and accomplished Financial Bid Form;	
	<input type="checkbox"/> (b) Original of duly signed and accomplished Price Schedule(s); and	
	TO:	
	II. FINANCIAL COMPONENT ENVELOPE	
	<input type="checkbox"/> (a) Original of duly signed and accomplished Financial Bid Form;	
	<input type="checkbox"/> (b) Original of duly signed and accomplished Price Schedule(s); and	
	<input type="checkbox"/> (c) Bill of Quantities.	

B. RESPONSE TO QUERIES

QUERY/ISSUE	BAC/END-USER RESPONSE/CLARIFICATION
What is the preferred cold air distribution method (i.e., In-row/Down-flow/Up-flow)?	In-row
May we request a copy of the Data Center floor plan for reference?	The Data Center is a container van measuring forty (40) feet. After an ocular visit, prospective bidders can create their own floor plan.
Can we request an ocular inspection to verify the needed materials and services for the installation?	Yes, the available ocular inspection for prospective bidders is on 07 March 2023. Kindly coordinate with the BAC Secretariat/Procurement Management Section for an appointment.
May we request a copy of the electrical as-built plan or Single-Line Diagram (SLD) of the facility for reference on the Uninterruptible Power Supply (UPS) set-up?	Please be informed that a copy of the electrical as-built plan or SLD of the facility shall be provided during the ocular inspection.
May we confirm the exact model/brand of the existing UPS for reference?	The brand of the existing UPS is Ablerex.
How many copies for the Technical and Financial components of bids for the manual submission?	Each Bidder shall submit one copy of the first and second components of its Bid. However, DOST-ASTI is requesting an additional copy. Hence, the bidders shall submit one (1) original and one (1) copy of their bids.

ADDITIONAL INSTRUCTION/S: Prospective bidder/s are required to: 1) amend the form to update existing information or 2) submit a copy of supplemental bulletin with statement of compliance or signature of authorized representative. **Non-compliance with this requirement shall be ground for disqualification.**

Please be guided accordingly.

Prepared by:

KATHERINE B. RAMOS
Head, DOST-ASTI BAC Secretariat

Approved by:

BAYANI BENJAMIN R. LARA
Chairperson, DOST-ASTI BAC