



11 April 2023

ASTI - BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL BULLETIN NO. BAC-2023-04-007

SUPPLY, DELIVERY, AND INSTALLATION OF ONE (1) LOT GLASS DOORS

The ASTI Bids and Awards Committee (BAC) issues this Supplemental/Bid Bulletin to clarify, modify or amend items in the Bidding Documents and to reply to queries raised by the potential bidders through letters/emails for the information of all bidders for the procurement of:

Item:	Supply, Delivery, and Installation of One (1) Lot Glass Doors
Approved Budget for the Contract:	One Million Four Hundred Thousand Pesos Only (₱1,400,000.00)
Invitation to Bid No.:	23-03-4300 dated 27 March 2023
Purchase Request Nos.:	GAA-23-02-16189 dated 20 March 2023
Published Date (PhilGEPS):	28 March 2023 9609770

A. AMENDMENT TO PROCUREMENT DETAILS AND FORMS

REFERENCE	AMENDMENT/CHANGE/CLARIFICATION		
Section VII. Technical Specifications, Page 33	FROM:		
	ITEM NO.	SPECIFICATIONS	STATEMENT OF COMPLIANCE
	1	Glass Doors	
		4. TECHNICAL SPECIFICATIONS	
		4.1. MAIN/FRONT ENTRANCE	
		4.1.1. Dimension	
		4.1.1.1. 7 meter/s x 2.30 meter/s	
		4.1.2. Frameless Automatic Sliding Door	
		4.1.2.1. Minimum: Two (2) 1 meter/s x 2.10 meter/s	
		4.1.3. Clear tempered glass for wall and door	
		4.1.3.1. 1/2 inches (Thickness)	
		4.1.4. Motorized (Automatic)	
		4.1.4.1. Motion sensor sliding glass door	
		4.1.5. Fixed Frameless Glass Wall	
		4.1.5.1. Four (4) Fixed Glass Wall	
		4.1.5.1.1. Minimum: 0.85 meter/s x 2.3 meter/s	
		4.1.5.2. Two (2) Fixed Glass Wall	
		4.1.5.2.1. Minimum: 0.8 meter/s x 2.3 meter/s	
		4.1.6. Sensor doors shall be equipped with manual transfer.	
		4.1.7. Dimensions given above may vary depending on the actual size and design of entrance. Minimum variations (+/-) shall be accepted by the end-user.	
		4.2. BACK ENTRANCE	
		4.2.1. Dimension	
		4.2.1.1. 3.7 meter/s x 2.30 meter/s	
		4.2.2. Frameless Sliding Door	
		4.2.2.1. Two (2) - 0.90 meter/s x 2.30 meter/s	
		4.2.3. Clear tempered glass for wall and door	
		4.2.3.1. 1/2 inches (Thickness)	
		4.2.4. Motorized (Automatic)	
		4.2.4.1. Motion sensor sliding glass door	
		4.2.5. Fixed Frameless Glass Wall	
	4.2.5.1. Two (2) 0.95 meter/s x 2.3 meter/s		
	4.2.6. Sensor doors shall be equipped with manual transfer.		

	4.2.7. Dimensions given above may vary depending on the actual size and design of entrance. Minimum variations (+/-) shall be accepted by the end-user.	
TO:		
ITEM NO.	SPECIFICATIONS	STATEMENT OF COMPLIANCE
1	Glass Doors	
	4. TECHNICAL SPECIFICATIONS	
	4.1. MAIN/FRONT ENTRANCE	
	4.1.1. Dimension	
	4.1.1.1. 7 meter/s x 2.30 meter/s 7 meter/s x 2.72 meter/s	
	4.1.2. Frameless Automatic Sliding Door	
	4.1.2.1. Minimum: Two (2) 1 meter/s x 2.10 meter/s Two (2) 1 meter/s x 2.72 meter/s	
	4.1.3. Clear tempered glass for wall and door	
	4.1.3.1. 1/2 inches (Thickness)	
	4.1.4. Motorized (Automatic)	
	4.1.4.1. Motion sensor sliding glass door	
	4.1.5. Fixed Frameless Glass Wall	
	4.1.5.1. Four (4) Fixed Glass Wall	
	4.1.5.1.1. Minimum: 0.85 meter/s x 2.3 meter/s Minimum: 0.85 meter/s x 2.72 meter/s	
	4.1.5.2. Two (2) Fixed Glass Wall	
	4.1.5.2.1. Minimum: 0.8 meter/s x 2.3 meter/s Minimum: 0.8 meter/s x 2.72 meter/s	
	4.1.6. Sensor doors shall be equipped with manual transfer.	
	4.1.7. Dimensions given above may vary depending on the actual size and design of entrance. Minimum variations (+/-) shall be accepted by the end-user.	
	4.2. BACK ENTRANCE	
	4.2.1. Dimension	
	4.2.1.1. 3.7 meter/s x 2.30 meter/s 3.7 meter/s x 2.66 meter/s	
	4.2.2. Frameless Sliding Door	
	4.2.2.1. Two (2) - 0.90 meter/s x 2.30 meter/s Two (2) - 0.90 meter/s x 2.66 meter/s	
	4.2.3. Clear tempered glass for wall and door	
	4.2.3.1. 1/2 inches (Thickness)	
	4.2.4. Motorized (Automatic)	
	4.2.4.1. Motion sensor sliding glass door	
	4.2.5. Fixed Frameless Glass Wall	
	4.2.5.1. Two (2) 0.95 meter/s x 2.3 meter/s Two (2) 0.95 meter/s x 2.66 meter/s	
	4.2.6. Sensor doors shall be equipped with manual transfer.	
	4.2.7. Dimensions given above may vary depending on the actual size and design of entrance. Minimum variations (+/-) shall be accepted by the end-user.	

B. RESPONSE TO QUERIES

QUERY/ISSUE	BAC/END-USER RESPONSE/CLARIFICATION
Requesting that the four (4) fixed glass on the side panels (front and back entrance), two (2) fixed glass walls, and transom panels will all be non-tempered glass and frameless but installed with a medium brown tint.	The specifications for the glass walls and doors to be clear and tempered will be retained, except for the amendments above.

Requesting that the two (2) automatic frameless sliding door will be tempered glass but with a medium brown tint.	
Requesting that the roof deck entrance be installed with a frameless tempered swing door and will have a medium tint. And the two fixed frameless glass walls will be installed with non-tempered glass but with a medium tint.	
We would also like to request a copy of the ground floor schedule of load and electrical plan for the power supply of the two automatic doors to be installed as to check the load requirement for the convenient outlet power supply.	Supplier shall conduct load assessment to determine the load requirement necessary for the convenient outlet power supply.
There are some papers/documents indicated in the Checklist that we do not prepare when joining bidding on infra projects (Technical Documents under letter "g"). Our question is, are there any alternative documents/papers we can use to comply so we can join the bidding for the glass doors?	Documents enumerated in Section VIII of the DOST-ASTI Philippine Bidding Documents (PBD) must be submitted.
The forms for SLCC and On-Going Projects are in different formats to what we use in the infra. Can we use the form we are using in the infra projects or do we need to use your form and indicate N/A for some details that infra projects don't have?	Forms in the DOST-ASTI PBD must be used by all prospective bidders.
For the accomplished price schedule, do you have any format or we will provide our own?	
There is a CHB wall (beside the existing glass doors) that needs to be demolished and restored for the automatic door to slide.	Demolition of CHB walls will be allowed, if necessary.

ADDITIONAL INSTRUCTION/S: Prospective bidder/s are required to: 1) amend the form to update existing information or 2) submit a copy of supplemental bulletin with statement of compliance or signature of authorized representative. **Non-compliance with this requirement shall be ground for disqualification.**

Please be guided accordingly.

Prepared by:

KATHERINE B. RAMOS
Head, BAC Secretariat

Approved by:

BAYANI BENJAMIN R. LARA
Chairperson, BAC